

**Features**

- System Board for HIMA, HIMax
- For 32-channel cards X-DI 32 01 or X-DI 32 04 (DI)
- For 16 modules
- Recommended modules: HiC2822 (DI), HiC2842 (DI)
- 24 V DC supply
- Hazardous area: spring terminals, blue
- Safe area: HIMA system connector, 96-pin

**Assembly**

**Function**

The function of the Termination Board and the connector pin assignment is exactly fitted to the requirements of HIMA system.

The signal is output to the process control system via the system connector.


Information about missing supply voltage of the isolated barriers is available for the system as volt-free contact. Wiring errors from field will be reported via the same relay contact if the isolated barriers support this function.

The Termination Board has a robust glass fiber reinforced plastic housing.

The Termination Board is mounted in the switch cabinet on a 35 mm DIN mounting rail according to EN 60175.



**Connection**



Release date 2015-05-05 15:18 Date of issue 2015-05-05 269873\_eng.xml




Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

Pepperl+Fuchs Group  
www.pepperl-fuchs.com

USA: +1 330 486 0002  
pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222  
pa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091  
pa-info@sg.pepperl-fuchs.com

<b>Supply</b>		
Connection		XG2: terminals 1, 3 (+); 2, 4 (-)
Rated voltage	$U_n$	24 V DC , in consideration of rated voltage of used isolated barriers
Voltage drop		0.9 V , voltage drop across the series diode on the Termination Board must be considered
Ripple		≤ 10 %
Fusing		4 A , in each case for 16 modules
Power loss		≤ 500 mW , without modules
Reverse polarity protection		yes
<b>Redundancy</b>		
Supply		Redundancy available. The supply for the modules is decoupled, monitored and fused.
<b>Error message output</b>		
Connection		XG2: terminals 5, 6
Output type		volt-free contact
Contact loading		30 V DC, 1 A
<b>Indicators/settings</b>		
Display elements		LED PWR1 (Termination Board power supply), green LED LED PWR2 (Termination Board power supply), green LED LED FAULT (fault indication), red LED - LED lits: power supply failure - LED flashes: module failure LED Run, green LED - The HIMax I/O module is supplied with power and is connected to the Termination Board (FTA) via a system cable. LED Field, red LED - The HIMax I/O module detects faults in the connection between HIMax I/O module and Termination Board (FTA).
<b>Directive conformity</b>		
Electromagnetic compatibility		
Directive 2004/108/EC		EN 61326-1:2013
<b>Conformity</b>		
Electromagnetic compatibility		NE 21:2012 For further information see system description.
Degree of protection		IEC 60529:2001
<b>Ambient conditions</b>		
Ambient temperature		-20 ... 60 °C (-4 ... 140 °F)
Storage temperature		-40 ... 85 °C (-40 ... 185 °F)
<b>Mechanical specifications</b>		
Degree of protection		IP20
Connection		hazardous area connection (field side): spring terminals, blue safe area connection (control side): HIMA system connector, 96-pin power supply connection: pluggable spring terminals, black
Core cross-section		0.25 ... 1.5 mm <sup>2</sup> (24 ... 16 AWG)
Material		housing: polycarbonate, 10 % glass fiber reinforced
Mass		approx. 800 g
Dimensions		266 x 200 x 163 mm (10.5 x 7.9 x 6.42 in) , height including module assembly
Mounting		on 35 mm DIN mounting rail acc. to EN 60715:2001
<b>Data for application in connection with Ex-areas</b>		
EC-Type Examination Certificate		CESI 06 ATEX 022 , for additional certificates see <a href="http://www.pepperl-fuchs.com">www.pepperl-fuchs.com</a>
Group, category, type of protection		 II (1)G [Ex ia Ga] IIC  II (1)D [Ex ia Da] IIIC  I (M1) [Ex ia Ma] I
<b>Safe area</b>		
Maximum safe voltage		250 V (Attention! $U_m$ is no rated voltage.)
<b>Electrical isolation</b>		
Field circuit/control circuit		safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V
<b>Directive conformity</b>		
Directive 94/9/EC		EN 60079-0:2012+A11:2013 , EN 60079-11:2012 , EN 60079-26:2007 , EN 50303:2000
<b>International approvals</b>		
UL approval		
Control drawing		116-0327
IECEX approval		IECEX CES 06.0003
Approved for		[Ex ia Ga] IIC [Ex ia Da] IIIC [Ex ia Ma] I
<b>General information</b>		

Release date 2015-05-05 15:18 Date of issue 2015-05-05 269873\_eng.xml

Supplementary information	EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see <a href="http://www.pepperl-fuchs.com">www.pepperl-fuchs.com</a> .
<b>Accessories</b>	
Designation	optional accessories: Label Carrier HiALC-Hi*TB-SET-1**

Release date 2015-05-05 15:18 Date of issue 2015-05-05 269873\_eng.xml

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

Pepperl+Fuchs Group  
www.pepperl-fuchs.com


USA: +1 330 486 0002  
pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222  
pa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091  
pa-info@sg.pepperl-fuchs.com

Application

Typical loop



Module switch settings

Type	Channel	DIP switch	Position
HiC2822 (DI), HiC2842 (DI) • Mode of operation: close – energized open – de-energized • Input line fault detection: enabled	1	S1	II
		S2	I
	2	S3	II
		S4	I



The pin-out configuration has to be observed. For information see corresponding pin-out table on [www.pepperl-fuchs.com](http://www.pepperl-fuchs.com).

Release date 2015-05-05 15:18 Date of issue 2015-05-05 269873\_eng.xml