



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX TUR 14.0035X	Page 1 of 4	<u>Certificate history:</u>
Status:	Current	Issue No: 4	Issue 3 (2023-11-21)
Date of Issue:	2024-07-09		Issue 2 (2023-03-21)
Applicant:	HIMA Paul Hildebrandt GmbH Albert-Bassermann-Str. 28 68782 Brühl Deutschland Germany		Issue 1 (2021-04-07)
Equipment:	HIMax System		Issue 0 (2016-02-01)
Optional accessory:			
Type of Protection:	Ex ec nC		
Marking:	Ex ec IIC T4 Gc Ex ec nC IIC T4 Gc		

Approved for issue on behalf of the IECEx
Certification Body:

Christian Mehrhoff

Position:

Assigned certifier

Signature:
(for printed version)

Date:
(for printed version)

2024-07-09

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

TUV Rheinland Industrie Service GmbH
Am Grauen Stein
51105 Cologne
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX TUR 14.0035X**

Page 2 of 4

Date of issue: 2024-07-09

Issue No: 4

Manufacturer: **HIMA Paul Hildebrandt GmbH**
Albert-Bassermann-Str. 28
68782 Brühl
Deutschland
Germany

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-15:2017](#) Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
Edition:5.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/TUR/ExTR14.0031/04](#)

Quality Assessment Report:

[DE/TUR/QAR24.0006/00](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX TUR 14.0035X**

Page 3 of 4

Date of issue: 2024-07-09

Issue No: 4

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

HIMax System

for further details see attachment

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The system shall be supplied with a SELV or PELV supply only.
2. The equipment shall only be used in an area of not more than pollution degree 2, as defined in IEC 60664-1.
3. The equipment shall be installed in an enclosure that provides a degree of protection not less than IP 54 in accordance with IEC 60079-0.
4. The information of the HIMax safety manual concerning the selection criteria for the enclosure (ability of heat dissipation) has to be considered.



IECEX Certificate of Conformity

Certificate No.: **IECEX TUR 14.0035X**

Page 4 of 4

Date of issue: 2024-07-09

Issue No: 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

The Certificate has been updated with the new QAR number.

Annex:

[DE-IECEX_TUR_14.0035X_04_Attachment.pdf](#)



Device: HIMax

Manufacturer: HIMA Paul Hildebrandt GmbH

Address: Albert-Bassermann-Str. 28
68782 Brühl
Germany

General product information:

HIMax is a safety-related control system and is intended for continuous operation. HIMax is a modular system. Functions such as processing, input and output, and communication are distributed on plug-in modules. These modules must be inserted in one or multiple base plates. A controller specific to the concrete application can be created by selecting appropriate modules. Ethernet cables are used to interconnect the base plates.

Technical Data:

Rated voltage: 20.4 ... 28.8 V DC

Ambient temperature: $0^{\circ} \leq T_a \leq 60^{\circ}C$

HIMax system modules:

Type	Description
X-BASE PLATE	Base Plate
X-FAN nn 01/02	System Fan for Base Plate
X-FAN nn 03/04	System Fan for Base Plate
X-SB 01	System Bus Module (SIL3)
X-CPU 01	Processor Module for high performance requirements and critical control applications (4 x RJ-45, SIL 3)
X-CPU 31	Processor module for small and midsize safety applications (2x RJ-45, SIL 3)
X-COM 01	Communication Module (4 x RJ-45, 2 x 9-pole D-Sub, up to 6 different Protocols)
X-COM 01 E	Communication Module (4 x RJ-45, 1 x 9-pole D-Sub, up to 6 different Protocols)
X-AI 16 51	Analog Input/ Temperature Module (16 Channels, galvanically isolated channels, TC, Pt100, 4...20 mA, +/-280 mV, SIL 1)
X-AI 32 01	Analog Input Module (32 Channels, 4...20 mA, Line Monitoring, SIL 3)
X-AI 32 02	Analog Input Module (32 Channels, 4...20 mA, SOE, Line Monitoring, SIL 3)
X-AI 32 51	Analog Input Module (32 Channels, 4...20 mA, Line Monitoring)
X-AO 16 01	Analog Output Module (16 Channels, 4...20 mA, pairwise galvanically isolated, SIL 3)
X-AO 16 51	Analog Output Module (16 Channels, 4...20 mA)
X-CI 24 01	Counter Module (24 Channels, 0...20 kHz, SIL 3)
X-CI 24 51	Counter Module (24 Channels, 0...20 kHz)
X-DI 16 01	Digital Input Module (16 Channels, 120 VAC, SIL 3)
X-DI 32 01	Digital Input Module (32 Channels, 24 VDC, SIL 3)
X-DI 32 02	Digital Input Module (32 Channels, 8.2 VDC, Proximity Switch, Line Monitoring, SIL 3)
X-DI 32 03	Digital Input Module (32 Channels, 48 VDC, SIL 3)
X-DI 32 04	Digital Input Module (32 Channels, 24 VDC, SOE, SIL 3)
X-DI 32 05	Digital Input Module (32 Channels, 8.2 VDC, Proximity Switch, Line Monitoring, SOE, SIL 3)
X-DI 32 51	Digital Input Module (32 Channels, 24 VDC)



Attachment to Certificate
IECEX TUR 14.0035 X
Revision 04

X-DI 32 52	Digital Input Module (32 Channels, 8.2 VDC, Proximity Switch)
X-DI 64 01	Digital Input Module (64 Channels, 24 VDC, SIL 3)
X-DI 64 51	Digital Input Module (64 Channels, 24 VDC)
X-DO 12 01	Relay Output Module (12 Channels, 230 VAC/DC, Current Measurement, Cycle Counting, SIL 3)
X-DO 12 02	Digital Output Module (12 Channels, 24 VDC, 2 A, Short-Circuit Monitoring LS, Individual Channel Shut-Off, SIL 3)
X-DO 12 51	Relay Output Module (12 Channels, 230 VAC/DC)
X-DO 24 01	Digital Output Module (24 Channels, 24 VDC, 0.5 A, Line Monitoring LS/LB, SIL 3)
X-DO 24 02	Digital Output Module (24 Channels, 48 VDC, 0.5 A, Line Monitoring LS/LB, SIL 3)
X-DO 32 01	Digital Output Module (32 Channels, 24 VDC, 0.5 A, Short-Circuit Monitoring LS, Individual Channel Shut-Off, SIL 3)
X-DO 32 51	Digital Output Module (32 Channels, 24 VDC, 0.5 A, Protected Outputs, Group Shut-Off)
X-HART 32 01	HART Interface Module (32 Modems, SIL 3)
X-MIO 7/6 01	Over Speed Trip Module (3 Counter, 4 digital Input, 5 digital Output, 1 Relay Channels, SIL 3)
X-DI 32 01 A	Digital Input Module (32 Channels, 24 VDC, SIL 3)
X-DI 32 02 A	Digital Input Module (32 Channels, 8.2 VDC, Proximity Switch, Line Monitoring, SIL 3)
X-AI 32 01 A	Analog Input Module (32 Channels, 4...20 mA, Line Monitoring, SIL 3)
X-DI 64 01 A	Digital Input Module (64 Channels, 24 VDC, SIL 3)
X-DO 24 01 A	Digital Output Module (24 Channels, 24 VDC, 0.5 A, Line Monitoring LS/LB, SIL 3)
X-DO 32 01 A	Digital Output Module (32 Channels, 24 VDC, 0.5 A, Short-Circuit Monitoring LS, Individual Channel Shut-Off, SIL 3)

Accessories:

- communication modules CM-***
- connector boards X-CB-*** **
- field termination assemblies X-FTA *** **