

Certificate



Certificate no.

CU 72180378 01

License Holder:

HIMA Paul Hildebrandt GmbH
Albert-Bassermann-Str. 28
68782 Brühl
Germany

Manufacturing Plant:

HIMA Paul Hildebrandt GmbH
Albert-Bassermann-Str. 28
68782 Brühl
Germany

Test report no.: USA-DS 31783660 001

Client Reference: Karl-Heinz Kruse

Tested to: UL 508:1999 R10.13
CAN/CSA C22.2.14-13

Certified Product: Safety Logic Controller

License Fee - Units

Model Designation: HIMatrix CSG 01, HIMatrix CSG 02,
HIMatrix CSG 03, HIMatrix CSG 04

7

Rated Voltage: DC 24V (SELV/PELV)
Rated Current: 8A (with max. loads)
Rated Power: 192W
Operating Temperature: 0° to 60°C

Special Remarks: Additionally evaluated to NFPA 85:2015,
NFPA 86:2015, NFPA 87:2018 and ANSI/ISA TR 84.00.05

7

Appendix: 1, 1-3

Licensed Test mark:



Date of Issue
(day/mo/yr)
08/05/2018