



Product Service

# CERTIFICATE

No. Z10 019183 0057 Rev. 00

**Holder of Certificate:** HIMA Paul Hildebrandt GmbH  
Albert-Bassermann-Str. 28  
68782 Brühl  
GERMANY

**Certification Mark:**



**Product:** Automation Equipment, Safety Related  
Modules of the Planar 4 system

**Model(s):** PLANAR 4 Series

**Parameters:** The report HB87155C in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met.

Operating voltage: 24 V DC  
Design: Eurocard

**Tested according to:** IEC 61508-1:2010 (SIL4)  
IEC 61508-2:2010 (SIL4)  
IEC 61508-3:2010 (SIL4)  
IEC 61508-4:2010 (SIL4)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** HB87155C

**Valid until:** 2026-02-25  
**Date,** 2021-02-26

( Peerasan Supavatanakul )