



Product Service

# CERTIFICATE

No. Z10 16 08 19183 053

**Holder of Certificate:** HIMA Paul Hildebrandt GmbH  
Albert-Bassermann-Str. 28  
68782 Brühl  
GERMANY

**Factory(ies):** 19183

**Certification Mark:**



**Product:** Safety-Related Programmable Systems

**Model(s):** HIMatrix F30, HIMatrix F35, HIMatrix F60,  
HIMatrix Remote I/O

**Parameters:** Operating voltage: 24 VDC -20% +25%

**Tested according to:**  
EN 50126:1999 SIL4  
EN 50129:2003 SIL4  
EN 50128:2011 SIL4  
IEC 61508-1(ed.2) SIL3  
IEC 61508-2(ed.2) SIL3  
IEC 61508-3(ed.2) SIL3  
IEC 61508-4(ed.2) SIL3

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** HB82132C

**Valid until:** 2021-08-09

**Date,** 2016-08-10 ( Peter Weiss )

Page 1 of 1